

REQUEST FOR PROPOSALS
Construction Services
Biosolids Facility Aeration Upgrades
Project #2504-1504

ADDENDUM #3

Issued June 16, 2026

1.2 Proposal Submission

The Closing Date of the Request for Proposals has been changed from 3:00PM (local time), Wednesday, June 17, 2026, to **3:00PM (local time), Friday, July 03, 2026.**

3.1 Background Information

Soft Start Cabinet Dimensions

The existing soft start cabinets are 19" wide x 49" long. There are 2 depths, 7.25" deep and 10.875" deep.

The intention was for the cabinets to be re-used for the VFDs. If this is not possible, the Municipality will require wall mounted units to replace the soft start cabinets. Arrangements for visits to the site can be made by emailing Kaela MacLellan, kmaclellan@colchester.ca.

All dimensions are to be verified by the successful proponent prior to procurement.

END OF ADDENDUM #3

